

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162367, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, May 05, 2017

Partial Correction
2 Misc

OK TO POUR WHEN READY TRENCH FOOTING AND INTEGRAL
SQUARE FOOTINGS AT UPPER LEVEL BLDG FROM (A) TO (P);
UFER GROUND JUMPER INSTALLED AT SOUTH END

Comments: