



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20160939 Date: May 08, 2017
Project Title: WILSHIRE AT LAKEWOOD Applicant:
MEMORY CARE
Location: 3320 NE WILSHIRE DR, LEES SLK ELECTRONICS INC
SUMMIT, MO 64064 14623 GAMMON RD
GREENWOOD, MO 64034
Type of Work: Primary: (816) 540-4308
Occupancy Group: I-1
Description: NEW MEMORY CARE
FACILITY WITH FULL
COMMERCIAL KITCHEN
Construction Type: Type VA (1 hour)
Map Page: 175L

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the fire alarm system and devices will be required prior to the final occupancy inspection. To schedule testing contact the fire department at 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.