

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, May 09, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY GWB CEILING /SOFFIT /LIGHT COVE FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING 1ST FLOOR SPACES: VESTIBULE @ MEN'S & WOMEN'S RESTROOMS 102 / 103; SOFFITS/FACIAS @ C104 LAB, 1-101, 1-117, 1-118; LIGHT COVE @ 1-151; HARD LID SOFFIT FIRST FLOOR AREA C A156; RR'S 102 & 103; A202; C202; C250; 206; 259; TENSION STUDS AT LIGHT SLOT CEILING AT N.2/9.3; BULKHEAD AT B152 E&S; HARD LID SOFFIT TENSION STUDS @ 4-150/151 & 152; BULKHEADS @ 4-101, 102, 103; SOFFIT AT CORRIDOR B155 EAST SIDE; TENSION STUDS SUPPORTING SOFFITS AT B151, B152; ROLLER SHADE POCKETS AT "C" A252 AND AT "A" A201; SOFFIT @ 3-250; SOFFIT + EYEBROW @ 205 INTNL STUDIES; [1-102 THRU 1-114; 1-117; 4-150 THRU 4-152; BULKHEADS AT 100A,100B, 2-150, 2-151; LIGHT COVE AT 4-156 & 4-157; SHADE POCKETS AT 2-101, 2-204, 2-205, 4-250 THRU 4-253; **TWO SHADE POCKETS AT B206;**

Comments: