

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20162811  
**Address:** 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086  
**Inspected On:** Tuesday, May 09, 2017  
**Inspected By:** John BornsJoe Dir  
**Expiration Date:** 5/18/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Tuesday, May 09, 2017

**Corrective Action Required:**

1	Misc	RAISED PLATFORM DINING AREA NOT APPROVED FOR USE UNTIL REQUIRED HANDRAILS ARE INSTALLED AND APPROVED.
---	------	--

**Corrective Action Required:**

5	Misc	IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST: NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR BEFORE ANY USE IS APPROVED.
---	------	---

<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Tuesday, May 09, 2017
--	---------	--------	--------------------------

