

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170992, Building Permit - Residential
Address: 1348 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Khanh Nguyen	Partial	Tuesday, May 09, 2017

Corrective Action Required

1	Misc	-THE WATER SERVICE LINE FROM THE METER TO THE MAIN HAS A COUPLING NEAR THE STREET CURB, DUE TO LONG LENGTH ACROSS THE STREET. NEED APPROVAL OF PUBLIC WORKS. EVERYTHING ELSE IS OK
---	------	--

Comments:

THE INSTALLER SAID THAT PUBLIC WORKS ALREADY LOOKED AND APPROVED THE NON-CONTINUOUS WATER LINE