

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161178, Building Permit - Commercial  
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 10, 2017

Partial Correction  
1 Misc

OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: **#2\*; 4; 5; 7\*;**

**\*GROUND RODS NOT PRESENTLY IN PLACE:**

<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 10, 2017
--	------------	---------	-------------------------

Partial Correction  
1 Misc

EXTERIOR WALL SHEATHING: NAIL PATTERN SUBSTANTIALLY COMPLETED CORRECTLY; SOME AREAS POINTED OUT TO BE CHECKED AND CORRECTED AS NECESSARY

Partial Correction  
2 Misc

**FRAMER TO INSTALL TRUSS WEB BRACING WHERE MISSING IN ADVANCE OF ABOVE-CEILING INSULATION INSTALLATION; ALSO AT DOUBLE TRUSSES BOTTOM CHORDS ARE TO BE FULLY NAILED TIGHT. THEN OK TO INSULATE AND INSTALL CEILING GWB.**

**Comments:**