

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161178, Building Permit - Commercial  
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

**Gas Piping Inspection -** John Borns  
**Commercial**

Partial

Wednesday, May 10, 2017

Partial Correction

1 Misc

**GAS PIPING PRESSURE TEST HELD STEADY AT  $\geq 10$  PSI FOR  $\geq 10$  MIN. ON PIPING EAST OF (EE) EXCLUDING RISER(S) TO ROOFTOP EQUIPMENT**

**NO ISSUES FOUND ON VISUAL INSPECTION OF SAME**

**Comments:**