

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171247, Public Works Infrastructure Permit - Commercial

Saint Luke's - OR Expansion #2

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:
Inspection:
Inspector:
Outcome:

PW-Sanitary Sewer
John DiMauro
Passed
Thursday,
Construction Inspection
Informational

1 John DiMauro 05/11/2017 10:58 AM

The crew on site removed the existing sanitary sewer manhole and the 6" & 8" PVC pipes. They installed a new 20'ft section of 6" PVC and tied it to the existing 6" pipe. They also installed 100.90'ft of 8" PVC pipe and tied it into two new manholes.

Comments: