LEE'S SUMMIT

## PUBLIC WORKS ENGINEERING DIVISION

## **Inspection Summary**

Permit #: PRPWFC20171247, Public Works Infrastructure Permit - Commercial Saint Luke's - OR Expansion #2 Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:		Inspector:	Outcome:	Date:
PW-Roof Drain		John DiMauro	Partial	Thursday, May 11, 2017
Informatio	onal			•
1	John DiMauro 05/11/2017 11:21 AM Crew is on site working on the installation of the roof drain structures.			
PW-Sanitary Sewer Construction Inspection Informational		John DiMauro	Passed	Thursday, May 11, 2017
1	Iohn DiMauro 05/11/2017 10:58 AM The crew on site removed the existing sanitary sewer manhole and the 6" & 8" PVC pipes. They installed a new 20'ft section of 6" PVC and tied it to the existing 6" pipe. They also installed 100.90'ft of 8" PVC pipe and tied it into two new manholes.			
PW-Storm - Sewer Construction Inspection Informational		John DiMauro	Partial	Thursday, May 11, 2017
1		/2017 11:10 AM he existing storm sewer struc the new pipe and roof drain s	-	e in the

## Comments:

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1800 | 816.969.1810 Fax | cityofLS.net/Development