LEE'S SUMMIT

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171247, Public Works Infrastructure Permit - Commercial Saint Luke's - OR Expansion #2 Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:						
Inspection:	Inspector:	Outcome:	Date:			
PW-Erosion Sedimen (ESC) Inspection Informational	t Control John DiMauro	Partial	Thursday, May 11, 2017			
1 John DiMau	ıro 05/08/2017 9:56 AM					
	ge 1 erosion control devices are	installed per the plans a	and intact.			
Informational						
2 John DiMauro 05/11/2017 11:28 AM						
The erosior	The erosion control devices are intact.					
PW-Sanitary Sewer	John DiMauro	Passed	Thursday,			
Construction Inspect	on		May 11, 2017			
Informational						
1 John DiMau	ıro 05/11/2017 10:58 AM					
The crew of	The crew on site removed the existing sanitary sewer manhole and the 6" & 8" PVC pipes.					
They install	They installed a new 20'ft section of 6" PVC and tied it to the existing 6" pipe. They also					
installed 10	installed 100.90'ft of 8" PVC pipe and tied it into two new manholes.					
PW-Storm - Sewer	John DiMauro	Partial	Thursday,			
Construction Inspect	May 11, 2017					
Informational			, ,			
1 John DiMau	John DiMauro 05/11/2017 11:10 AM					
The crew re	The crew removed the existing storm sewer structure and 12" R.C.P. They are in the					
process of i	process of installing the new pipe and roof drain structures this morning.					

PW-Roo	f Drain	John DiMauro	Partial	Thursday, May 11, 2017		
Informati	ional					
1	John DiMauro 05/11/2017 11:21 AM					
	Crew is on site working on the installation of the roof drain structures.					
PW-Site Visit		John DiMauro	Partial	Thursday,		
_				May 11, 2017		
Informational						
1	John DiMauro 05/08/2017 10:02 AM					
	Crews are on site working.					
Informational						
2	John DiMauro 05/09/2017 10:34 AM					
	Crews are on site today working on the storm sewer relocation.					
Informational						
3	John DiMauro 05/10/2017 3:40 PM					
	Crews on site today working on the strom and sanitary sewer lines.					
Informat	•	C				
4 John DiMauro 05/11/2017 11:25 AM						
-	Crews on site working on the utility plans.					

Comments: