

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Friday, May 12, 2017

Corrective Action Required
1 Misc

****INSPECTED ZONE A AND C CORRIDOR AND BATHROOMS
PRE-ROCK FOR CEILING ONLY: INSTALL 2 H-CLIPS AT EACH END
OF ALL GIRDERS; MISSING SOME HANGERS AND H-CLIPS IN ZONE
C; SUPPORT ONE TRUSS IN ZONE A NEAR MIDDLE OF CORRIDOR**

Comments: