PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162246, Building Permit - Residential Address: 1333 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Monday, May 15, 2017

Codes Residential

Corrective Action Required

1 Misc -OBTAIN LAWN IRRIGATION PERMIT

-HOUSE PERMIT INCLUDE FINISHED BASEMENT, BUT THE BASEMENT IS CURRENTLY NOT FINISHED. HAVE THE PERMIT

CHANGED TO OMIT FINISHED BASEMENT -DECK PIERS WERE NOT INSPECTED

-EXPOSE SEWER TRACER BOX

-COMPLETE DECK BOTTOM STAIR LANDING
-INSTALL FLOOD LIGHT AT REAR OF HOUSE

-INSTALL A RECEPTACLE WITHIN 25 FT OF THE AC UNIT

-INSTALL SPARK RING FOR RECEPTACLE BOX AT PANTRY AND AT

MASTER BATH

-PROVIDE MIN. 12" HOR. CLEARANCE FROM SHELF TO CLOSET

LUMINAIRE

-PROVIDE STAIR ILLUMINATION CONTROLLED BY SWITCHES AT

TOP&BOTTOM STAIR LANDING

-INSTALL A RECEPTACLE IN UNFINISHED PORTION OF BASEMENT

UNDER STOOP

Comments: