

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20160642, Public Works Infrastructure Permit - Commercial
Missouri Innovation Campus
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Proof roll parking lot	Steve Robbins	Partial	Monday, May 15, 2017

Informational

- 1 On friday we did a proofroll on the north side of the parking lot. The special inspector was also there and it passed. We had a truck with 18 tons .Steve Robbins 05/15/2017 7:41 AM

PW-Street - Base Lift	Steve Robbins	Partial	Monday, May 15, 2017
-----------------------	---------------	---------	----------------------

Informational

- 1 The 4" of base rock was installed today on the north end of the parking lot. They will start on the base and curbs soon going around the back side of the building.Steve Robbins 05/15/2017 12:07 PM

Comments: