

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162861, Building Permit - Residential
Address: 3333 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, May 15, 2017

All Rough Inspection - Residential	Mike Copeland	Failed	Monday, May 15, 2017
---	---------------	--------	----------------------

Corrective Action Required

1 Misc

-Plans do not show the short-walls over the headers/LVL along perimeter of great room; also do not show the LVL crossing above the great room, which supports the roof. Resolution will likely require engineer report and/or alteration of plans.

-Install straps at wall plates that are bored more than 50% for passage of plumbing.

okay to insulate

Piers/Caissons Inspection - Residential	Mike Copeland	Passed	Monday, May 15, 2017
--	---------------	--------	----------------------

Comments: