

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Monday, May 15, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT: MDP RM C162 EXCEPT NW CORNER WHERE TIE-DOWN HAS YET TO BE APPROVED;

Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, May 15, 2017
---	------------	---------	----------------------

Partial Correction
1 Misc

OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #2*; 4; 5; 7*;

*GROUND RODS NOT PRESENTLY IN PLACE.

Partial Correction
2 Misc

OK TO COVER WHEN READY TRENCHED PVC CONDUIT: FROM L.P.#2 ONE 1" TO 80' WEST + ONE 3/4" TO 28' WEST CONN TO EXSTG; **ONE 1" FROM PL#2 TO 45' NE FOR BL; ONE 1" ~80' ACROSS FRONT ENTRANCE FROM BL TO BL; ONE 3/4" FROM LP#7 ~110' NW FOR BL;**

Comments: