



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

May 16, 2017

INFORM STUDIO  
235 E MAIN ST STE 102B  
NORTHVILLE, MI 48167

Permit No: PRCOM20170985  
Project Title: VERIZON TI  
Project Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081  
Parcel Number: 51700031300000000  
Location: CHIPMAN HWY 50--- LOT 12  
Type of Work: CHANGE OF TENANT  
Occupancy Group:  
Description: COMMERCIAL TENANT FINISH

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. ACTION REQUIRED: (information purposes)  
Have the fire alarm system contractor provide shop drawings for any modifications to be done to the fire alarm system.

3. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).  
ACTION REQUIRED: (verified at inspection)

Post the numeric address of 1740 in a contrasting color on the exterior of the front door and any other door leading into the suite. The address shall be readable from the roadway.

4. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

Have the fire sprinkler system contractor provide shop drawings for any modifications to be done to the fire sprinkler system.

5. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Testing of any modifications to the fire alarm system will be required prior to the final occupancy inspection. To schedule a test contact the fire department at 816-969-1300.

6. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide a minimum of two 2A-10BC fire extinguishers. Mount the fire extinguishers on a normal path of travel close to an exit.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

2. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is for informational purposes.

5/15/17 - acknowledged

3. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

5/15/17 - acknowledged

7. 2012 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Provide verification that POS furniture will be accessible.

5/15/17 - acknowledged via manufacturer's cut-sheet. To be field verified.

11. 2012 IMC 602.2.1 Materials within plenums. Except as required by Sections 602.2.1.1 through 602.2.1.5, materials within plenums shall be noncombustible or shall be listed and labeled as having a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested in accordance with ASTM E84 or UL 723. (see code section for exceptions)

Action required: Comment is for informational purposes. PVC is not allowed in plenums. To be verified during inspections.

5/15/17 - acknowledged - field verify

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***