

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161966, Building Permit - Residential  
Address: 312 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Dale Carter	Failed	Tuesday, May 16, 2017

### Corrective Action Required

1 Misc

#### REQUIRED FOR TCofO:

-PART OF THE DECK IS ATTACHED TO A CANTILEVERED PORTION OF THE HOUSE.

Update: Attempted resolution is not adequate. Recommend alteration at direction of an Engineer.

#### REQUIRED FOR FULL CofO:

-INSTALL FINAL GRADE, SOD, SPLASHBLOCKS

### Comments: