

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161758, Building Permit - Commercial  
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Failed	Tuesday, May 16, 2017
Partial Correction 1        Misc		OK TO COVER WHEN READY EXTERIOR WALL SHEATHING	
Partial Correction 2        Misc		NO STRUCTURAL ISSUES FOUND TO PREVENT INTERIOR MEP WORK FROM PROCEEDING	
Corrective Action Required 3        Misc		NAILING OF ROOF SHEATHING PREDOMINATELY OVERDRIVEN	

**Comments:**