

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20162991, Building Permit - Residential

Address: 2143 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822145 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822147 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822141 SW TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Sidewalk Inspection	John DiMauro	Partial	Tuesday, May 16, 2017

Informational

1 John DiMauro 05/16/2017 2:59 PM
The sidewalk cross slope is less than 2.0%
I informed the contractor that the ADA section needs to be adjusted to meet the standard specs.

Comments: