

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162991, Building Permit - Residential
Address: 2143 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822145 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822147 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822141 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Passed	Tuesday, May 16, 2017

Electrical Service Inspection - Residential	Mark Harding	Passed	Tuesday, May 16, 2017
--	--------------	--------	-----------------------

All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, May 16, 2017
---	--------------	--------	-----------------------

Corrective Action Required

1	Misc	- nail blocking on front bedroom to rafters 2137 install protection plate at bedroom wall / back of shower water lines ok to insulate
---	------	---

PW-Sidewalk Inspection	John DiMauro	Partial	Tuesday, May 16, 2017
-------------------------------	--------------	---------	-----------------------

Comments: