

Temporary Certificate of Occupancy

Permit #: PRRES20160568
Address: 425 SE MILL CREEK DR, LEES SUMMIT, MO 64063
Inspected On: Wednesday, May 17, 2017
Inspected By: Mike Copeland
Expiration Date: 5/31/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|------------------|----------------------------|
| Occupancy Inspection - Codes Residential | Mike Copeland | Temporary C of O | Wednesday, May 17, 2017 |

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -OBTAIN SIDEWALK APPROVAL -EXTEND SUMP PUMP 36" FROM FOUNDATION OR INSTALL SPLASHBLOCK, INSTALL SPLASHBLOCK NW CORNER OF HOUSE -SEAL FRONT LIGHT FIXTURES SUITABLE FOR WET LOCATIONS |
|---|------|---|