

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, May 17, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL
SYSTEMS AT: MDP RM C162; **110; 111; 136; 137; 138; 143; 145;
148; 149; 154; 155; 156;**

**COVER NO FRAMED WALLS ALONG NORTH CMU WALL WHERE
FIRE-BLOCKING IS NOT DONE & APPROVED.**

Comments: