

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162367, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, May 17, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY BURIED PVC SECONDARY ELECTRICAL SERVICE CONDUIT: THREE 3" FROM XFRMR LOC SOUTH OF S END OF HIGH SIDE OF BLDG TO BLDG ENTRY; **THREE 3" FROM XFRMR LOC NW OF N END OF HIGH SIDE OF BLDG TO BLDG ENTRY @ N END;**

Comments: