

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162403, Building Permit - Commercial  
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 17, 2017

Partial Correction

1	Misc	ELECTRICAL EQUIPMENT GROUNDS FOUND TIED THROUGH AT 1ST FLOOR BOXES. DRYWALL GAPS AROUND BOXES HAVE BEEN MUDDERED FULL.
---	------	--

**Comments: BEFORE INSTALLING ELECTRICAL SWITCHES AND RECEPTACLES REMOVE ALL DRYWALL MUD FROM INSIDE BOXES.**