

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20163237, Building Permit - Residential  
Address: 1340 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, May 18, 2017

Corrective Action Required

1	Misc	-NAIL GARAGE EXTERIOR WALL SIDING TO SILL PER CODE
		-ANCHOR SILL PLATES WITHIN 12" OF BREAKS THROUGHOUT
		-BRACE LVL BEAM ENDS FROM ROTRATION
		-FIREBLOCKING: FB FIREPLACE SPACE; FB WALL AT THERMOSTAT; FB BASEMENT WALL SPACE AND SPACE BY BASEMENT BATH SHOWER FROM FURDOWN CEILING SPACE

\*\*\*OK TO INSULATE

<b>Gas Service Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, May 18, 2017
---	--------------	--------	------------------------

**Comments:**