

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20162993, Building Permit - Residential

Address: 2133 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822135 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822137 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822131 SW TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Passed	Thursday, May 18, 2017

Informational

1 John DiMauro 05/15/2017 11:09 AM
The driveway approach cross slope is less than 2.0%

Comments: