

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, May 19, 2017
Partial Correction 3 Misc		RATED DOOR HEAD ASSEMBLIES PER DETAILS 11/A7.03 & 12/A7.03: OPENING 2-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE; 1ST LAYER 5/8" TYPE X GWB; OPENING 4-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE; 1ST LAYER 5/8" TYPE X GWB; OPENING 2-200: FRAMING & LINER BOARD @ INSIDE(W) FACE;	
All Rough Inspection - Commercial	John Borns	Partial	Friday, May 19, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY WOOD FRAMING & ENCLOSED SYSTEMS @ UNDER-STAIR SPACES AT: 1ST LEVEL A-COMMONS, C-COMMONS; SPRINKLER PIPING + GUARD & UNDERSTAIR FRAMING AT COMMONS 100 STAIR;	
Above Ceiling Inspection	John Borns	Partial	Friday, May 19, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY GWB CEILING /SOFFIT /LIGHT COVE	

FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING 1ST FLOOR SPACES: VESTIBULE @ MEN'S & WOMEN'S RESTROOMS 102 / 103; SOFFITS/FACIAS @ C104 LAB, 1-101, 1-117, 1-118; LIGHT COVE @ 1-151; HARD LID SOFFIT FIRST FLOOR AREA C A156; RR'S 102 & 103; A202; C202; C250; 206; 259; TENSION STUDS AT LIGHT SLOT CEILING AT N.2/9.3; BULKHEAD AT B152 E&S; HARD LID SOFFIT TENSION STUDS @ 4-150/151 & 152; BULKHEADS @ 4-101, 102, 103; SOFFIT AT CORRIDOR B155 EAST SIDE; TENSION STUDS SUPPORTING SOFFITS AT B151, B152; ROLLER SHADE POCKETS AT "C" A252 AND AT "A" A201; SOFFIT @ 3-250; SOFFIT + EYEBROW @ 205 INTNL STUDIES; [1-102 THRU 1-114; 1-117; 4-150 THRU 4-152; BULKHEADS AT 100A,100B, 2-150, 2-151; LIGHT COVE AT 4-156 & 4-157; SHADE POCKETS AT 2-101, 2-204, 2-205, 4-250 THRU 4-253; SHADE POCKETS AT B206; OUTER BAND OF FRAMING AROUND CLOUD CEILINGS AT B150 & B151; **THREE CLOUD CEILINGS AT B150 & B151; TENSION STUDS SUPPORTING SOFFITS AT B250, B251, B252, TWO AT B207;**

Partial Correction
2 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING & ENCLOSED SYSTEMS PER A/E RIVISION "METAL SHROUD LIGHT DETAIL" DTD 3/28/17: AT 10.25/W-Y AND 10.75/J-L; 10/I-K; 10.5/I-K; Q/3 - Q/3.5; U/3 - U/3.5; G/4 - G/4.5; J/4 - J/4.5;

Partial Correction
3 Misc

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:

A153C; A153D; A161; A163;

C101; C102; C102A; C103; C103A; C104; C105; C106; C154; C155; C155A; C155B; C156A;

Comments: