

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, May 19, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY COMPONENTS OF RATED WALL ASSEMBLIES: PRE-ROCK ON S WALL OF SPACE 110 ONCE TAPED & MUDDERED;	
Partial Correction 2 Misc		OK TO COVER WHEN READY COMPONENTS OF UL P522 RATED CEILING ASSEMBLIES AT SPACES: 136-138; 159; 162;	
In-wall Inspection	John Borns	Partial	Friday, May 19, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT: MDP RM C162; 110; 111; 136; 137; 138; 143; 145; 148; 149; 154; 155; 156; [106; 107; 127; 128; 131; 133; 134; 135; 157; 159; 162;	

Comments: