

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161756, Building Permit - Commercial  
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, May 19, 2017

Partial Correction  
1 Misc

RATED ASSEMBLY AT STAIRWELLS:  
OK TO COVER 5/8" TYPE X MOLD TOUGH GWB AT **NORTH STAIRWELL WALLS**: 2ND LAYER AT 1ST LEVEL WELL FACE + 1ST LAYER PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 2ND LEVEL WELL FACE;

OK TO COVER 5/8" TYPE X MOLD TOUGH GWB AT **SOUTH STAIRWELL WALLS**: 2ND LAYER AT 1ST LEVEL WELL FACE + 1ST LAYER PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 2ND LEVEL WELL FACE;

Partial Correction  
2 Misc

OK TO COVER WHEN READY RATED ASSEMBLY AT ELEVATOR SHAFT: 1ST LAYER PERIMETER PRE-ROCK AT JOIST SPACE;

**Comments:**