

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161933, Building Permit - Commercial  
Address: 783 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Monday, May 22, 2017

Corrective Action Required

1	Misc	ROOF SHEATHING AT SOUTH DETACHED GARAGE: SUFFICIENT NUMBER OF NAILS, BUT ALL OVERDRIVEN
		ROOF SHEATHING AT NORTH GARAGE NOT COMPLETED FOR INSPECTION

**Comments:**