

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Monday, May 22, 2017

Partial Correction
1 Misc

RATED CEILING ASSY OK BELOW:
-ZONE A CORRIDOR&BATH ONLY-1ST LAYER OK
-ZONE C CORRIDOR&BATH ONLY-1ST LAYER OK

Comments: