

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161624, Building Permit - Residential  
Address: 3349 SW JESSIE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                               |               |          |                       |
|-------------------------------|---------------|----------|-----------------------|
| Inspection:                   | Inspector:    | Outcome: | Date:                 |
| <b>Occupancy Inspection -</b> | Mike Copeland | Failed   | Tuesday, May 23, 2017 |
| <b>Codes Residential</b>      |               |          |                       |

### Corrective Action Required

- |   |      |    |                                                                           |
|---|------|----|---------------------------------------------------------------------------|
| 1 | Misc | 1. | Final grade, sod.                                                         |
|   |      | 2. | Garage to be self closing.                                                |
|   |      | 3. | Install 4 three inch screws rear door at the strike side and 2 per hinge. |
|   |      | 4. | Basement bath GFCI not re setting.                                        |
|   |      | 5. | Secure SE cable within 12" of the panel.                                  |
|   |      | 6. | Anchor columns in basement.                                               |
|   |      | 7. | Obtain final sidewalk approval.                                           |

**Comments:**