

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, May 23, 2017

Partial Correction		
1	Misc	ELEVATOR SHAFT: ENSURE TIE-DOWN CLIPS AT ROOF TRUSS BEARING; THEN OK TO APPLY GWB LID PER APPROVED DRAWINGS

Rated Assembly Inspection	John Borns	Partial	Tuesday, May 23, 2017
--------------------------------------	------------	---------	-----------------------

Partial Correction		
1	Misc	ELEVATOR SHAFT LID: FRAMING AND SHAFT LINER BOARD OK TO COVER;

Comments: