

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162552, Public Works Infrastructure Permit - Commercial
SUMMIT SQUARE APARTMENTS
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Street - Base Lift	Steve Robbins	Passed	Wednesday, May 24, 2017

Informational

1 The base asphalt has been installed in front of buildings 3 and 4 and the road for the round about. Steve Robbins 05/24/2017 7:32 AM

PW-Street - Proof Roll	Steve Robbins	Passed	Wednesday, May 24, 2017
------------------------	---------------	--------	----------------------------

Informational

1 We did a proofroll for the lower parking lot and and parking garages on the lower level by the north entrance. This portion passed except for on area that we marked with paint and they came back and dug in out and let it dry and replaced with more rock. We did another proofroll and it was good. Steve Robbins 05/11/2017 7:16 AM

Informational

1 The proofroll has been completed and passed for the road in front of and around buildings 3 and 4. Steve Robbins 05/24/2017 7:29 AM

Comments: