

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170161, Building Permit - Residential  
Address: 1695 NE PARKWOOD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, May 24, 2017

### Corrective Action Required

1	Misc	-INSTALL STRAPS FOR THE GARAGE PORTAL BRACE WALLS **I MEAN STRAP THE INNER SIDES OF THE PORTAL BRACE WALLS OR JUST PUT SOME MORE NAILING OF THE H-FRAMES INTO THE LVL HEADER  -FIREBLOCK FIREPLACE SPACE FROM ATTIC; FB BASEMENT WALL SPACE FROM CEILING FURDOWN SPACE **AT FIREPLACE, FB OPENINGS AT FRONT UPPER CORNERS OF FIREPLACE SPACE. FB GAPS ALONG THE TOP OF THE FIREPLACE SPACE **IN BASEMENT, FB NOT DONE  ****OK TO INSULATE
---	------	---

**Comments:**