

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, May 25, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT: STAIRWELL 3-156 1ST LEVEL; **WALL**
"BUMP-OUT" AT MAIN COMMONS AT MAIN STAIR;

Comments: