

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20163096, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underground Electrical Inspection - Commercial | John Borns | Partial | Thursday, May 25, 2017 |

Partial Correction

| | | |
|---|------|--|
| 1 | Misc | OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM: TWO 1" PVC CONDUITS ACROSS NORTH DRIVEWAY APRON + TWO 1-1/2" PVC CONDUITS TO 70' WEST INTO PARKING LOT, EAST END OF WHICH IS TO BE EXTENDED/BORED EAST TO REAR OF MAIN BUILDING; FROM EXISTING QUAZITE BOX AT PRINT MARK (30) TO NEW Q-BOX AT (31) ; FROM Q-BOX AT (32) TO EXISTING WALL-MOUNTED J.B. AT (33); |
|---|------|--|

Partial Correction

| | | |
|---|------|---|
| 2 | Misc | OK TO POUR WHEN READY LIGHT POLE BASES: ALL EXCEPT A,15 |
|---|------|---|

Partial Correction

| | | |
|---|------|--|
| 3 | Misc | OK TO COVER WHEN READY BURIED CONDUIT TO LIGHT POLE LOCATIONS: FROM L.P. B,8 TO B,9 TO B,10; FROM B,10 TO A,12 TO A,13; FROM L.P. A,15 TO HANDHOLE BOX ~20 N/NE |
|---|------|--|

Comments: