

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162367, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|------------|----------|------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underground Electrical Inspection - Commercial | John Borns | Partial | Thursday, May 25, 2017 |

Partial Correction

| | | |
|---|------|--|
| 1 | Misc | OK TO COVER WHEN READY BURIED PVC SECONDARY ELECTRICAL SERVICE CONDUIT: THREE 3" FROM XFRMR LOC SOUTH OF S END OF HIGH SIDE OF BLDG TO BLDG ENTRY; THREE 3" FROM XFRMR LOC NW OF N END OF HIGH SIDE OF BLDG TO BLDG ENTRY @ N END; |
|---|------|--|

Partial Correction

| | | |
|---|------|--|
| 2 | Misc | OK TO COVER WHEN READY CONDUITS FROM UPPER LEVEL BUILDING W/NW TO Q-BOX LOCATION IN ISLAND THEN TO SPACE BETWEEN THE DETACHED GARAGE BUILDINGS -- ONE 3/4", ONE 1", ONE 1-1/4"; |
|---|------|--|

Comments: