

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, May 25, 2017

Partial Correction

1	Misc	EXTERIOR WALL FOOTING-OK TO POUR UPON APPROVAL FROM ON-SITE SPECIAL INSPECTOR: -ZONE A,B&C-EXT. WALL GB, THICKEN SLAB, AND PADS-APPROVED -ZONE B REAR PATIO FIREPLACE AND CONNECTED GB-OK *UFER INSTALLED AT WEST SIDE OF Z. A
---	------	---

Comments: