

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Not Ready	Friday, May 26, 2017

Corrective Action Required
2 Misc

INSTALL NO CEILING TILE BEFORE ABOVE-CEILING INSPECTION --
EXCEPT THOSE FEW REQUIRED FOR MOUNTING OF DEVICES.

Comments: