

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162560, Building Permit - Residential
Address: 1332 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Failed	Friday, May 26, 2017

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | 1. Property address shall be capable of being illuminated.
2. Obtain sprinkler permit.
3. Final grade; erosion control; splashblocks.
4. Receptacle cover over fireplace not seated - leaves live conductors exposed.
5. Receptacles in laundry room are within 6-feet of sink and should be GFCI protected.
6. Install four (4) 3-inch security screws through metal jamb-plate at downstairs entry door. |
|---|------|---|

Comments: