

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170199, Building Permit - Residential

Address: 2203 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822205 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822207 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822201 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Friday, May 26, 2017

All Rough Inspection - Residential	Mark Harding	Failed	Friday, May 26, 2017
---	--------------	--------	----------------------

Corrective Action Required

1	Misc	2201 fire wall incomplete in attic , check all units at ridge a. complete all firewalls, holes, repairs throughout. nail all coner studs all units. install wall bracing all units required. -nail rafters to blocking front bed room 2nd floor -2203 notched floor joist for 3" dwv -firestop dryer vent and bathroom 1st floor. - firestop dead space at 1st floor shower -2205 firestop heat ducts to 2nd floor -firestop dryer vent through top plate - 2207 firestop dryer vent plumbing protection plates at kitchen vent.
---	------	---

**Rated Assembly
Inspection**

Mark Harding

Failed

Friday, May 26, 2017

Comments: