

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162330, Building Permit - Residential
Address: 1308 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, May 30, 2017

Corrective Action Required

1	Misc	-PROVIDE CS-PF WALL AT REAR DINING AREA CORNER
		-FIREBLOCKING: FB ALL BASEMENT WALL SPACE FROM CEILING FURDOWN SPACE AT FRONT BASEMENT BED CLOSET
		-DOUBLE UP THE GARAGE ATTIC ACCESS TRIMMER JOISTS
		-INSTALL LVL BEAM AT STAIR PER PLAN
		-NOTCHED JOIST BELOW FRONT BATH SHOWER
		**SUPPORT JOIST AS DISCUSSED
		***OK TO INSULATE

Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Tuesday, May 30, 2017
----------------------------------------------------	--------------	--------	-----------------------

Comments: