

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162367, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Passed	Tuesday, May 30, 2017
Foundation Inspection - Commercial	John Borns	Passed	Tuesday, May 30, 2017

Comments: OK TO POUR WHEN READY STEM WALLS ON EARLIER-POURED FOOTING AND SLAB AT NORTH AND SOUTH ENDS OF UPPER LEVEL BUILDING.