

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160836, Building Permit - Commercial
Address: 2641 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, May 31, 2017

Corrective Action Required

1	Misc	-4 LIGHT POLE PIERS OK; HOWEVER, THE UNDERGROUND RACEWAY MUST BE MIN. 24" BELOW THE DRIVEWAY&PARKING LOT
---	------	--

Comments: