

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162048, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, May 31, 2017

Corrective Action Required

1	Misc	SHELL PERMIT MUST BE CLOSED FOR COFO TO BE ISSUED.
---	------	--

Corrective Action Required

2	Misc	FIRE-STOPPING OF EAST WALL OF ELECTRICAL ROOM TO BE COMPLETED.
---	------	--

Partial Correction

3	Misc	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. STAFFING, TRAINING, FIXTURING, STOCKING OK. NO PUBLIC/CUSTOMERS PRIOR TO APPROVAL.
---	------	--

Occupancy Inspection - Fire	Michael Weissenbach	No remaining issues	Wednesday, May 31, 2017
------------------------------------	---------------------	---------------------	-------------------------

Comments: