

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152455, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Failed	Wednesday, May 31, 2017

Corrective Action Required

1	Misc	HANDRAILS REQUIRED AT SIDEWALK STAIR NORTH OF NORTH END OF BUILDING.
---	------	--

DECORATIVE STONEWORK IN PROGRESS WEST AND NORTH OF THE BUILDING

Corrective Action Required

2	Misc
---	------

Corrective Action Required

3	Misc
---	------

ROOFTOP GAS PIPING:  
- DIRT LEG CAPS MUST CLEAR ROOF SURFACE FOR REMOVAL AND REPLACEMENT AND MAINTENANCE  
- PIPE CLAMPS MISSING AT SOME PIPE SUPPORTS

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Temporary C of O	Wednesday, May 31, 2017
------------------------------------	---------------------	------------------	-------------------------

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Temporary C of O	Wednesday, May 31, 2017
------------------------------------	---------------------	------------------	-------------------------

<b>Occupancy Inspection - Planning</b>	John Borns	Passed	Wednesday, May 31, 2017
--	------------	--------	-------------------------

<b>Occupancy Inspection - Water Utilities</b>	Curtis Deason	Passed	Wednesday, May 31, 2017
---	---------------	--------	-------------------------

<b>Alarm Test</b>	Joe Dir	Passed	Wednesday, May 31, 2017
-------------------	---------	--------	-------------------------

**Comments:**