

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, June 01, 2017
Partial Correction			
1 Misc		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT: STAIRWELL 3-156 1ST LEVEL; WALL "BUMP-OUT" AT MAIN COMMONS 1ST LEVEL AT MAIN STAIR; "BUMP-OUT" AT MAIN COMMONS 1ST LEVEL SOUTHWEST; "BUMP-OUT" AT MAIN COMMONS @ FIRE HOSE CABINET AT 2ND LEVEL SOUTHWEST; SPACE D254; B208 (NORTH WALL B/F); 3-226; AT/ADJACENT TO DOOR OPENING 4-150.1;	

Rated Assembly Inspection	John Borns	Partial	Thursday, June 01, 2017
Partial Correction			
1 Misc		RATED DOOR HEAD ASSEMBLIES PER DETAILS 11/A7.03 & 12/A7.03: OPENING 2-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE; 1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB; OPENING 4-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE; 1ST LAYER 5/8" TYPE X GWB AT WALLS/BULKHEAD; 2ND LAYER 5/8" TYPE X GWB AT WALLS/BULKHEAD; FRAMING & SHAFT LINER BOARD AT CEILING; 1ST LAYER 5/8" TYPE X GWB AT CEILING; 2ND LAYER 5/8" TYPE X GWB AT CEILING; OPENING 2-200: FRAMING & LINER BOARD @ INSIDE(W) FACE; 1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB;	

OPENING 2-204: FRAMING & LINER BOARD @ INSIDE(W) FACE;
1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB;

FRAMING & LINER BOARD @ N WALL OF B208;

Comments: