

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170199, Building Permit - Residential

Address: 2203 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822205 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822207 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822201 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Thursday, June 01, 2017

### Corrective Action Required

1	Misc	2201 fire wall incomplete in atttic , check all units at ridge a. complete all firewalls, holes, repairs throughout. nail all coner studs all units. -2203 notched floor josit for 3" dwv -
---	------	---

**Comments:**