

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162861, Building Permit - Residential
Address: 3333 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Dale Carter	Failed	Friday, June 02, 2017

Corrective Action Required

1	Misc	-Plans do not show the short-walls over the headers/LVL along perimeter of great room; also do not show the LVL crossing above the great room, which supports the roof. Resolution will likely require engineer report and/or alteration of plans. okay to insulate
---	------	--

Comments: